

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7165-1483:116 Page 1 of 1

**CATEGORY:** Control Unit (Non High-Rise)

**LISTEE:** Mirtone, 90 Fieldstone Ct., Cheshire, CT 06410  
Contact: Brad Miller (888) 649-9827 Fax (203) 699-3108

**DESIGN:** Models MIR-2Z3, MIR-2Z3R, MIR-2Z6, MIR-2Z6R fire alarm control units. Local, auxiliary, central station, remote station, automatic, manual, waterflow and sprinkler supervisory service. System components:

MODEL	PART NUMBER	DESCRIPTION
2IDC	PP#46213-2101	2 Zone Initiating Module
N/A	PP#46213-2102	Base Module
N/A	PP#46213-2103	Power Supply
BPAC	PP#46213-2104	Base Panel Class A Converter
IDCA	PP#46213-2105	IDC Module Class A Converter
RCT-1	PP#46213-2106	Relay-City Tie (FDR) Module
ADMM	PP#130279	Annunciator Master Module
ADSM	PP#130284	Annunciator Slave Module
DL1	PP#46213-2058	Digital Alarm Comm Transmitter

Refer to listee's data sheet for additional detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as fire alarm control units for use with separately listed compatible initiating and indicating devices.

**NOTE:** For Fire Alarm Verification Feature, the maximum Retard/Reset/Restart period must be adjusted to 30 seconds or less.

This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

**XLF:** 7165-1388:177

06-03-97



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**